

# model 7501BLH

120V Insulated, Portable Blanket (Haz Loc)

## FEATURES & BENEFITS

#### **TEMPERED WATER**

Heated, insulated blanket provides ANSI compliant tempered water in operating temperatures to -20° F (-30° C). Unit will stay tempered in non-extreme outdoor conditions (below 100° F (38° C)). Mounted over the Haws model 7501.

#### **HAZARDOUS LOCATION**

Complies with requirements for hazardous locations Class I, Division 2, Groups B, C, D, Temperature code T4; Class II, Division 2, Groups F, G

### **OPTIONS**

For more information, visit www.hawsco.com or call (888) 640-4297.




## **SPECIFICATIONS**

Model 7501BLH NEMA 4, heated, insulated blanket to provide ANSI compliant tempered water in operating temperatures to -20° F (-30° C). The self-contained blanket easily installs on to existing model 7501. Eyewash and heating blanket offered as a package or individually. 120VAC, 60Hz, 1.38A electrical requirement. Power cord not provided – power connection must be made according to code using Class I Division 2 compliant equipment. Voltage options available. CSA certified for NEMA/Type 4 in Class 1, Division 2, Group B, C, D, T6, and Class 2, Division 2, Group F, G locations; and to ANSI/ISEA Z358.1

**APPLICATIONS** 



THIS DOCUMENT IS TRUE AND CORRECT AT TIME OF PUBLICATION. CONTINUED PRODUCT IMPROVEMENTS MAKE SPECIFICATIONS AND MEASUREMENTS SUBJECT TO CHANGE WITHOUT NOTICE.



### MODEL 7501BLH / 7501BL240H ELECTRICAL DETAIL

#### FOR MODELS 7501BLH & 7501BL240H:

- 1. ALL MODELS MUST HAVE A GROUND FAULT PROTECTION DEVICE (30mA GFCI) FOR HEAT TRACE. ELECTRICAL CURRENTS MAY BE INSUFFICIENT TO TRIP A CONVENTIONAL CIRCUIT BREAKER. ALL INSTALLATIONS MUST BE INSTALLED IN COMPLIANCE WITH LOCAL, STATE, AND/OR FEDERAL CODES.
- 2. ALL POWER CONNECTIONS MUST BE MADE ACCORDING TO NEC/CEC CODE USING FLEXIBLE CONDUIT OR CABLE RATED FOR NEMA/TYPE 4 NO RIGID CONNECTION PERMITTED. MODEL 7501BLH/ 7501BL240H REQUIRES MINIMUM NEMA/TYPE 4 COMPLIANT EQUIPMENT. THE CORD AND FITTINGS SELECTED MUST HAVE THE APPROPRIATE HAZARDOUS LOCATION RATING REQUIRED FOR THE INSTALLATION LOCATION.



1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWSCO.COM WEBSITE: WWW.HAWSCO.COM

ECN NO. REVISED PER BY: 5235 | ECN: 5235 | ECN: 5235 | CC |
DRAWN: DATE: CHKD: 7501BLH / 7501BL240H
CC | 12/28/17 MJ | ELECTRICAL SCHEMATIC

7501BLH / 7501BL240H
ELECTRICAL SCHEMATIC

0510000809.D
REVISION
1